

**Centennial School District/Powell Butte Elementary
2017 Radon Testing Results**

| Site Name | Building Name | Room Description (per floor plan) | Date sampled 3/7/17 Results (pCi/L) | Type of test | Date resampled 5/1/17 Results (pCi/L) |
|-------------------------|---------------|--------------------------------------|---|--------------|---|
| Powell Butte Elementary | Main Building | Office admin | 2.6 | Detector kit | |
| Powell Butte Elementary | Main Building | Health rm | 3.1 | Detector kit | |
| Powell Butte Elementary | Main Building | Principal | 3.3 | Detector kit | |
| Powell Butte Elementary | Main Building | Staff wkrm | 3.0 | Detector kit | |
| Powell Butte Elementary | Main Building | 13 | 6.7 | Detector kit | 3.40 |
| Powell Butte Elementary | Main Building | 32 | 2.9 | Detector kit | |
| Powell Butte Elementary | Main Building | 31 | 2.6 | Detector kit | |
| Powell Butte Elementary | Main Building | Staff lounge | 6.4 | Detector kit | 1.90 |
| Powell Butte Elementary | Main Building | 15 Music | 2.9 | Detector kit | |
| Powell Butte Elementary | Main Building | 17 | 5.5 | Detector kit | 0.80 |
| Powell Butte Elementary | Main Building | 19 | 5.0 | Detector kit | 1.30 |
| Powell Butte Elementary | Main Building | 21 | 1.7 | Detector kit | |
| Powell Butte Elementary | Main Building | 23 | 6.9 | Detector kit | Needs a retest |
| Powell Butte Elementary | Main Building | 25 | 4.5 | Detector kit | 1.10 |
| Powell Butte Elementary | Main Building | 26 | 5.6 | Detector kit | 1.50 |
| Powell Butte Elementary | Main Building | 24 | 6.0 | Detector kit | 1.40 |
| Powell Butte Elementary | Main Building | 22 | 8.6 | Detector kit | 1.80 |
| Powell Butte Elementary | Main Building | 20 | 6.3 | Detector kit | 1.20 |
| Powell Butte Elementary | Main Building | 18 | 9.4 | Detector kit | 0.90 |
| Powell Butte Elementary | Main Building | 16 | 4.4 | Detector kit | 0.70 |
| Powell Butte Elementary | Main Building | 14 | 4.6 | Detector kit | 0.50 |
| Powell Butte Elementary | Main Building | 27/Psych | 4.9 | Detector kit | 0.80 |
| Powell Butte Elementary | Main Building | 28 Office | 3.6 | Detector kit | |
| Powell Butte Elementary | Main Building | 28 | 4.1 | Detector kit | 0.80 |
| Powell Butte Elementary | Main Building | Library 1 series | 3.4 | Detector kit | |
| Powell Butte Elementary | Main Building | Library 2 desk | 3.4 | Detector kit | |
| Powell Butte Elementary | Main Building | Library office | 5.3 | Detector kit | 1.70 |

| | | | | | |
|-------------------------|---------------|----------------|------|--------------|------|
| Powell Butte Elementary | Main Building | Library wkrm | 6.6 | Detector kit | 2.00 |
| Powell Butte Elementary | Main Building | Staff wkrm | 5.2 | | 2.10 |
| Powell Butte Elementary | Main Building | 33 | 5.0 | Detector kit | 1.00 |
| Powell Butte Elementary | Main Building | Copy rm | 3.0 | Detector kit | |
| Powell Butte Elementary | Main Building | 2 | 1.0 | Detector kit | |
| Powell Butte Elementary | Main Building | 4 | 3.9 | Detector kit | |
| Powell Butte Elementary | Main Building | 6 | 2.7 | Detector kit | |
| Powell Butte Elementary | Main Building | 8 | 2.3 | Detector kit | |
| Powell Butte Elementary | Main Building | 10 | 2.5 | Detector kit | |
| Powell Butte Elementary | Main Building | 12 | 3.9 | Detector kit | |
| Powell Butte Elementary | Main Building | 11 | 2.9 | Detector kit | |
| Powell Butte Elementary | Main Building | 9 | 2.1 | Detector kit | |
| Powell Butte Elementary | Main Building | 7 | 2.0 | Detector kit | |
| Powell Butte Elementary | Main Building | 3 | 3.2 | Detector kit | |
| Powell Butte Elementary | Main Building | 34 | 7.9 | Detector kit | 3.10 |
| Powell Butte Elementary | Main Building | Gym 1 | 2.9 | Detector kit | |
| Powell Butte Elementary | Main Building | Gym 2 | 2.8 | Detector kit | |
| Powell Butte Elementary | Main Building | Booster Club | 3.0 | Detector kit | |
| Powell Butte Elementary | Main Building | 35 Cook office | 6.3 | Detector kit | 4.30 |
| Powell Butte Elementary | Main Building | 36 PE office | 5.2 | Detector kit | 7.70 |
| Powell Butte Elementary | Main Building | 1000 | 29.7 | Detector kit | |
| Powell Butte Elementary | Main Building | 1001 | 24.3 | Detector kit | |

| |
|---------------------|
| Type of test |
|---------------------|

| |
|--------------|
| |
| |
| |
| |
| Detector kit |
| |
| |
| Detector kit |
| |
| Detector kit |
| Detector kit |
| |
| |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| Detector kit |
| |
| Detector kit |
| |
| |
| Detector kit |

| |
|--------------|
| Detector kit |
| Detector kit |
| Detector kit |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| Detector kit |
| |
| |
| |
| Detector kit |
| Detector kit |
| |
| |

To Be remediated
To Be remediated